## BATTERY CALCULATIONS FAP-001-16

ITEM	DESCRIPTION	QTY	STANDBY CURRENT PER ITEM (AMPS)	TOTAL STANDBY CURRENT PER ITEM	ALARM CURRENT PER ITEM (AMPS)	TOTAL ALARM CURRENT PER ITEM
CP-35	FACP w/2ZN'S + AUD	1	0.1750	0.1750	0.5010	0.5010
PS-35	POWER SUPPLY	1	0.0000	0.0000	0.0000	0.0000
BC-35	BATTERY CHARGER	1	0.0450	0.0450	0.0300	0.0300
PM-32	MATRIX MODULE	1	0.0000	0.0000	0.0000	0.0000
SM-30	SWITCH MODULE	1	0.0000	0.0000	0.0450	0.0450
SR-35	8 RELAY MODULE	1	0.0000	0.0000	0.0210	0.0210
ZN-34US	SUPERVISORY MODULE	1	0.0100	0.0100	0.1100	0.1100
ZU-35	ZONE MODULE	2	0.0090	0.0180	0.1100	0.2200
ZU-35DS	ZONE MODULE/SD's	1	0.0090	0.0090	0.1100	0.1100
SMOKE	SMOKE DETECTOR	1	0.0001	0.0001	0.0010	0.0010
MOI	TRANSMITTER	1	0.1200	0.1200	0.1750	0.1750
MID	INPUT BOARD	1	0.0020	0.0020	0.0000	0.0000
PS-5A	POWER SUPPLY	1	0.0380	0.0380	0.0000	0.0000
TOTAL NOTIFICATION APPLIANCES CURRENT						0.1000
	TOTAL SYSTEM CUF	RRENT	STANDBY	0.4171	ALARM	1.3130

MIN. BATTERY CAPACITY =  $\{(TOT. STANDBY CURRENT X STANDBY TIME) +$ 

(TOT. ALARM CURRENT X ALARM TIME)} X 1.25 MIN. BATTERY CAPACITY =  $\{(0.4171 \text{ A X } 24 \text{ HR}) + (1.3130 \text{ A X } 0.083 \text{ HR})\} \text{ X } 1.25$ 

MIN. BATTERY CAPACITY = {10.0104 AHr + 0.109 AHr} X 1.25 = 12.6492 AHr

## NOTIFICATION APPLIANCE CIRCUIT VOLTAGE DROP & POWER REQUIREMENTS

CKT AV1 — BLDG 16 DESCRIPTION	QTY	CURRENT PER ITEM (AMPS)	TOTAL CURRENT PER ITEM	
WHEELOCK STROBE 15 cd	_	0.5010	0.0000	
WHEELOCK HORN/STROBE 15cd	_	0.0000	0.0000	
WHEELOCK STROBE 30 cd	_	0.0300	0.0000	
WHEELOCK HORN/STROBE 30 cd	_	0.0450	0.0000	
WHEELOCK STROBE 75 cd	_	0.0210	0.0000	
WHEELOCK HORN/STROBE 75 cd	_	0.1100	0.0000	
WHEELOCK STROBE 110 cd	_	0.1100	0.0000	
WHEELOCK HORN/STROBE 110 cd	_	0.1750	0.0000	
WHEELOCK HORN	_	0.0000	0.0000	
AUTOCALL BELL	2	0.0500	0.1000	
TOTAL NOTIFICATION APPLIANCES CURRENT				

VOLTAGE DROP (VD) CALCULATIONS

 $VD = \{(I) (D) (21.6)\}/CM$ WHERE: I = CIRCUIT CURRENT

D = CONDUCTOR LENGTH (FT) ONE WAY

21.6 = A CONSTANTCM = CIRCULAR MILS

 $VD = \{(0.1A) (80FT) (21.64)\}/4110 = 0.042V$  $%VD = {0.042V / 24V} X 100 = 0.175%$ REMAINING VOLTS = 23.958

WIRE CIRCULAR SIZE MILS 12AWG 6530 14AWG 4110 16AWG 2580 18AWG 1620 20AWG 1020

AS BUILT

BLDG 16 FIRE ALARM FUNCTION CHART & CALCULATIONS

FIRE ALARM SYSTEM

FUNCTION CHART

SYSTEM EVENT

FIRE CALL BOX | • | •

SYSTEM FAULT • •

AC POWER FAILURE |

FIRE SPRINKLER WATERFLOW SWITCH • •

FIRE SPRINKLER VALVE SUPERVISORY SWITCH •

CHECKED BY LDD

APPROVED BY MCD 09/16/2013 09/16/2013 SCALE AS NOTED

UNIVERSITY OF CALIFORNIA LAWRENCE BERKELEY NATIONAL LABORATORY FACILITIES DIVISION

DRAWING NO. SHEET 4B16E018\_ PROJECT NO. 00000 1 OF 1

DATE 09/16/2013

LDD LDD MCD 09/16/13 AS BUILT ISSUE (PROGRESS, ESTIMATE, BID, CONSTRUCTION, CONFORMED, REVISION, RECORD)

LDD LDD MCD 09/16/13 AS BUILT PROGRESS, ESTIMATE, BID, CONSTRUCTION, NUMBER BY BY BY DATE REMARKS PROFESSIONAL SEAL (IF REVISION, APPLIES ONLY TO REVISED WORK)